

VILLAGE OF DEPEW

SEWER LATERAL REPAIR REQUIREMENTS

§ 187-19 Construction to conform to rules and regulations.

The size, slope, alignment, materials of construction of a building sewer, and the methods to be used in excavating, placing of the pipe, jointing, testing and backfilling the trench, shall all conform to the requirements of the building and plumbing code as set forth in appropriate specifications of the ASTM and WPCF Manual of Practice No. 9; and PVC pipe in accordance with ASTM D-3034 SDR 35, or SCH 40, Asbestos Cement Pipe, or Asbestos Cement Pipe in accordance with ASTM C-428 for sanitary sewers service shall cover size of all pipes used in normal sewer extensions and subdivisions and trunk lines and laterals.

§ 187-20 Required elevation of building sewer.

The building sewer shall be brought to the minimum of 10 inches above cellar floor. In all buildings in which any building drain is too low to permit gravity flow to the public sewer, sanitary sewage carried by such building drain shall be lifted by an approved means and discharged to the building sewer.

§ 187-21 Drainage connections to sanitary sewers prohibited.

No person shall make connection of roof downspouts, foundation drains, areaway drains or other sources of surface runoff or groundwater to a building sewer or building drain which in turn is connected directly or indirectly to a public sanitary sewer unless such connection is approved by the Superintendent for purposes of disposal of polluted surface drainage.

§ 187-22 Standards for connection to public sewer.

A. Applicable rules and regulations. The connection of the building sewer into the public sewer shall conform to the requirements of the building and plumbing New York State Uniform Fire Prevention and Building Code or other applicable rules and regulations of the Village, or the procedures set forth in appropriate specifications of the ASTM and the WPCF Manual of Practice No. 9. All such connections shall be made gastight and watertight and verified by proper testing. Any deviation from the prescribed procedures and materials must be approved by the superintendent before installation.

B. Superintendent to inspection connection. The applicant for the building sewer permit shall notify the Superintendent when the building sewer is ready for inspection and connection to the public sewer. The connection and testing shall be made under the supervision of the Superintendent or his or her representative.

C. Guarding of excavations; restoration. All excavations for building sewer installation shall be adequately guarded with barricades and lights so as to protect the public from hazard. Streets, sidewalks, parkways, and other public property disturbed in the course of the work shall be restored in a manner satisfactory to the Village.

IT IS RECOMMENDED THAT ALL CLAY TILE LATERALS BE REPLACED IN THEIR ENTIRERTY FROM FOUNDATION TO TAP.

RECEIVED

102012

DEPEW BLDG. DEPT